



Hurricane Valley Fire SSD

Fire Safety Business Inspection

202 E. State Street
Hurricane, UT 84737
435-635-9562

Business: _____

Address: _____

Phone: _____

Owner/Mgr. Name: _____

PASS ☐

FAIL ☐

Exterior Building

		Yes	No	N/A
1	Building Address			

Exits/Mean of Egress

2	Proper number of exit signs			
3	Exit signs illuminated			
4	Proper number of exits			
5	Clear egress'			

Riser/Sprinklers

6	Current Riser inspection tag			
7	RISER INSPECTION TAG EXPIRATION DATE			
8	Clear space around riser			
9	Access and clearance to FDC			
10	Sprinkler heads cannot be painted			

Extinguishers

11	Current inspection tag on extinguisher			
12	Proper number of extinguishers			
13	Proper placement of extinguishers			
14	Extinguisher located in a conspicuous location			

Electrical

15	Breaker panel marked			
16	36" of clearance in front of breaker panel			
17	No exposed electrical wiring components			
18	No extension cords and only fused power strips			

Fire Alarm/Escape

19	Off site monitoring tested for compliance			
20	Fire alarm working with no trouble lights			
21	Fire escape plans and practice records			
22	Smoke detectors must be interconnected			
23	Carbon monoxide detectors required in bedroom			

Storage

24	No high piled storage. Must be less than 24 inches from ceiling			
25	Gas cylinders chained to solid object			
26	No storage in furnace or water heater room			

General Safety

27	Door from home to garage must have self-closing hinges			
28	Dumpster location more than 5' from structure			
29	Floor plan on sheet of 8 ½ x 11 piece of paper			

Inspector's Signature

Inspector's Signature

Date